

## MEMBRANE ELEMENT

# **PMNF1-4040LF**

Low Fouling Technology & Low Energy Consumption

### **SPECIFICATIONS**

Nominal Membrane Area: 85 sq.ft

Permeate Flow: 1,900 gpd (7.1 m<sup>3</sup>/d)


NaCl Rejection: > 85% MgSO4 Rejection: 99%

Membrane Polymer: Polyamide Thin-Film Composite

Feed Spacer thickness: 34 mil (0.864mm)

The stated performance is based on the following conditions:

500 ppm NaCl, 2000 ppm MgSO4 70 psi (0.48 MPa) Applied Pressure 77 °F (25 °C) Operating Temperature 15% Permeate Recovery pH 7.5



A, inches (mm)	B, inches (mm)	C, inches (mm)	Weight, lbs. (kg)
40.0 (1016)	3.9 (99)	0.75 (19)	8 (3.6)

#### **OPERATING DATA**

Maximum Applied Pressure: 600 psig (4.16 MPa)

Free Chlorine Tolerance: < 0.1 ppm Maximum Operating Temperature:  $113 \,^{\circ}\text{F} \, (45 \,^{\circ}\text{C})$  Continuous pH Range (Cleaning):  $2.5 - 10.5 \, (2 - 12)$ 

Maximum Feedwater Turbidity: 1.0 NTU Maximum Feedwater SDI (15 mins): 5.0

Maximum Feed Flow: 16 gpm (3.6 m<sup>3</sup>/h)

Minimum Ratio of Concentrate to Permeate Flow for any Element: 5:1

Maximum Pressure Drop: 15 psi

#### NOTICE:

Permeate flow for individual element may vary + or - 15 percent. All membrane elements are supplied with a brine seal, interconnector and o-rings in a sealed polyethylene plastic bag. Use glycerin or silicon only, for lubrication of seals and o-rings. Static permeate back pressure must be always avoided. The information and data are offered in good faith, but without guarantee. Please refer to the application information literature entitled Operation Guidelines for more information before installing and operating the elements. Specifications can be modified without prior notice.

PERSALT MEMBRANES: 401 East Jackson Street Suite 2340, Tampa, FL 33602 Phone: (813) 803-6125 Fax: (813) 803-6126 – <a href="mailto:info@persalt.com">info@persalt.com</a>